

Search Results

You are here: [Home](#) » Search Results

Search by Company Name

Eurotech Fire Protection Ltd, in collaboration with Firetec Systems Ltd

Unit 6, The Business Centre

Molly Millars Lane

Wokingham

Berkshire

RG41 2QZ

United Kingdom

Tel: +44 1252 860606 • Fax: +44 1252 860606

Email: keith.goodall@EurotechFP.com • Web: www.firetec-systems.com

Certificate No 1222a to LPS 1230

Eurotech227 & Eurosafe227 - 25 bar & 42 bar HFC 227ea Gaseous Fire Suppression Systems

Product	Risk	Design Concentration	Comments	LPCB Ref. No.
Eurotech227 & Eurosafe227	Class A Standard (Solid fires e.g. paper, wood, plastics)	7.8%	Design concentration includes 30% safety factor	1222a/01
Eurotech227 & Eurosafe227	Class A Cables (Solid fires risks including cables)	8.2%	Confirmation that 'minimum safety factor' is adequate	1222a/01
Eurotech227 & Eurosafe227	Class B (Liquid Fires e.g.heptane)	9.2%	Design concentration includes 30% safety factor	1222a/01

Design concentration Class A Standard and Class B = Extinguishing concentration x safety factor (minimum 1.3).

Design concentrations are as tested to LPS 1230 In BRE Test Report Numbers 231870 (25 bar) & 254632 (42 bar) (Class A and B risks) and Test Letter 282069 (Class A Cables risks)

Extinguishing concentrations are as tested in BRE Test Report Number 231870 (ISO 14520-1 tests).

This system uses:

Design Manual: 'Eurotech Fire HFC227 Manual' - Issue 13-03

Software Programme : Vds Schadenverhutung calculation package version 7.3

This system is suitable for storage and environmental conditions from -20° to 50°C.

System pressure is specified as 25 bar and 42 bar at 20°.

To read the Red Book section introduction click here.

[< back to results page](#)

[< back to search page](#)



The BRE Group website family

BRE Global Approvals listings

[Terms of Use](#) | [How we use cookies](#) | Copyright BRE Global 2017