

## Search Results

You are here: [Home](#) » Search Results

### Search by Company Name

#### **Nitin Fire Protection Industries Ltd (NITIE)**

501 Delta  
Technology Street  
Hirandani Gardens, Powai  
Mumbai 400 076  
India

Tel: +91 22 40457000 • Fax: +91 22 66920910  
Email: [systems@nitinfire.com](mailto:systems@nitinfire.com) • Web: [www.nitinfire.com](http://www.nitinfire.com)

#### **Certificate No 855g to EN 12094-4**

### **Nitin227, Nitin1230 & Inertech Container Valve Actuators**

| Product | Description                              | LPCB<br>Ref. No. |
|---------|------------------------------------------|------------------|
| NF26010 | Solenoid Actuator                        | 855g/04          |
| NF26011 | Solenoid Actuator with reverse EMF diode | 855g/04          |
| NF26020 | Pneumatic Actuator                       | 855g/04          |
| NF26030 | Pneumatic/Manual Actuator                | 855g/04          |

#### **Nitin227 & Nitin1230 Firefighting Components:**

- This range of equipment is suitable for storage temperatures of -20°C to 50°C and is approved for use with HFC227ea and FK 5-1-12 (Novec<sup>TM</sup> 1230).
- HFC227ea equipment is approved for use in conjunction with Eurotech Fire Protection Ltd Design Manual Reference 'Eurotech Fire HFC227 Manual' - Issue 13-03.
  - FK 5-1-12 equipment is approved for use in conjunction with Eurotech Fire Protection Ltd Design Manual Reference 'Eurotech Fire Novec1230 Manual' - Issue 13-04.
  - Nominal system pressure for HFC227ea components at 20°C is stated at 25 bar or 42 bar.
  - Nominal system pressure for FK 5-1-12 components at 20°C is stated at 25 bar or 42 bar.

**[To read the Red Book section introduction click here.](#)**

[< back to results page](#)

[< back to search page](#)



---

The BRE Group website family

BRE Global Approvals listings

[Terms of Use](#) | [How we use cookies](#) | Copyright BRE Global 2017